



SUPPLEMENTAL/BID BULLETIN NO. 11

June 21, 2023

SUPPLY, DELIVERY, and INSTALLATION, with COMMISSIONING and TESTING of FLOW METER for VEGA and JUBILEEVILLE PUMP STATIONS CY 2023

Bid Reference No. **06-001-23** NOTICE TO BIDDERS

This is being issued to clarify and/or amend certain provisions in the Bidding Documents issued for this project, considering the issues raised and clarifications made by prospective bidders during the Pre-bid Conference held on June 20, 2023.

A. AMENDMENTS/ INCLUSIONS

Reference	Bases for Amendment
1. SECTION V. TECHNICAL SPECIFICATIONS a. Data logger can be external as long as compatible b. Modbus is the communication of current SCADA system c. 4-20mA output needed for the flow rate	<i>Clarifications of some specifications</i>

By Rules, amendments made herein are likewise deemed amended to conform to this Bid Bulletin and shall be considered an integral part of the Bidding Documents. All provisions of the Bidding Documents that are affected are deemed modified / amended / revised.

For further inquiries, you may coordinate with the Bids and Awards Committee at Telephone No. 049 536 4127 loc 106 or 02 8584 4271.

ENGR. JUAN PAULO BUENAAGUA
Chairman, LARC-BAC